

# System Evaluation & Audit Report

**Machine:** SDI ID 99287

**Type:** PAS 5500 /400C

**Report date:** February , 2020

## Contents

1.0 Introduction

2.0 Background

2.1 General Information

2.2 Configuration

3.0 Visual inspection

3.1 General information

3.2 Visual inspection analysis

4.0 Performance check

4.1 General information

4.2 Performance check analysis


5.0 Summary

6.0 Recommendations

7.0 Appendices

8.0 Performance reports

8.1 Material list



## 1.0 Introduction

- Fab facilities were up (temperature- and humidity- control, CDU/vacuum and lens gas)

### Machine SDI ID 99287:


Executed audit steps:

- Setup and Imaging lens qualification
- Record tests, as result from setup.
- Full visual inspection by picture making
- (historical) data collection

Situation at start of the audit:

- System was in production end 2019 (customer info) and idled down in December, 2019
- Facilities/supplies were connected including lens gas.
- 

The audit results are used to determine the quality of the system. Results and conclusions are part of this report.



## 2.0 Background Information

### 2.1 General information

System # SDI ID 99287  
 Type PAS 5500 /  
 400C  
 12NC 9428.999.60  
 490  
 Construction year 2001


Owner

Location

Last maintained 2020  
 (ASML)

### 2.2 Configuration

EQUIPMENT CLASSIFICATION	
Characteristic Description	Value
Valid ATP-document	Yes
Hertz	60 Hertz
Power	380 Volt
MES machine type	/400C
Position of Signal Tower	Local
1: Software release 5500	Sw rel. 8.8.6
SPM (ScribelanePrim.Mrk) Align	Standard
Optical Prealign (Mark Sensor)	Standard
Wafer size	200 mm
Wafer type	Notch
FAT Attendance	No (Data Review Only)
Standard warranty	1 Year
ATP Matching /500 /550	No ATP matching
Cassette (elevator) position	Cassette position 1 and 2
Wafer Track Interface	SCREEN (SOKUDO) 80/ D-Spin 200
SECS I and II Interface	Yes
Batch streaming	Advanced RMS
Tape streamer OCU-MK4 or less	Yes
Single Reticle Smif Handling	Yes
Signall (SW-only)	Yes
ASML TESTING: ProductivMonitor	Yes
ASML TESTING: ReliabilityMonit	Yes
PEP400B = /400B to /400C upgr	Standard
BA Reticle Tilt Measurement	Yes
Sourcing Level	Local Sourcing



### 3.0 Visual Inspection

#### 3.1 General

The goal of the visual inspection is to determine:


- Configuration & Completeness
- Technical status: defect- damaged- parts, contamination and corrosion, wear and tear.

System was in a working, operational state prior the visual inspection. A full visual inspection was done by making detailed pictures of all modules.

#### 3.2 Visual inspection Analysis

	<b>1</b>	No deviations
Legend:	<b>2</b>	Deviations found, medium performance impact/ris
	<b>3</b>	Deviations found, high performance impact/risk
	<b>4</b>	No information available

Component	Category	Score	Notes	Actions
<b>PROJECTION LENS</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>ILLUMINATION</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>RETICLE MANAGEMENT SYSTEM</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>RETICLE STAG</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>WAFER STAGE</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>LEVEL SENSOR (SP)</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>WAFER HANDLING (WTS+WPS)</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>MAIN BODY</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>ELECTRONIC CABINET</b>	COMPLETENESS	2		
	DAMAGES	1	missing panels, functional issue:	Replace missing panels
	CONTAMINATION	1	contamination	
<b>OPERATOR CONSOLE UNIT</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>S&amp;T CABINET</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>AIR CONTROL CABINET</b>	COMPLETENESS	1		
	DAMAGES	1		
	CONTAMINATION	1		
<b>CABLES &amp; HOSES</b>	COMPLETENESS	1		
	DAMAGES	2	water lines are original and should be replaced.	may develop water leak.
	CONTAMINATION	1		



## 4.0 Performance checks

### 4.1 General


- Input for the performance analysis:
- Performance test reports generated during Lens Qual. 2019/11
- Historical test data generated by the user until the end of 2019.

ASML engineering specialists analyzed the performance data.

In chapter 4.2 the performance analysis is presented.

### 4.2 Results

Legend:		1	Performance ok	
		2	Performance issue, medium impact/risk	
		3	Performance issue, high impact/risk	
		4	No performance data available	
ILLUMINATION	1		Slit Uniformity and scanning Dose in ATP spec	
IMAGING / LENS PERFORMANC	1			
Dynamics	1		Dynamic Performance all values in spec.	
FOCUS & LEVELLING	1			
Alignment	2		TTL Repro and TTL laser power in spec. OA Repro oos , OA red/Green laser in spec.	System need Athina setup after Green laser replacment.
Scanning Waferstage	1			
Scanning Reticle stage	1			
Waferhandling	1		Mark Sensor Repro and Edge Sensor repro, all values are in spec.	
ARMS	1			
C&T	1			
Overlay & Throughput	1			expect no issue since system performance is OK




## 5.0 Summary

### General:

- System is complete and in a working state (February, 2020)
- The system has high stray light uniformity values. This may be corrected by cleaning the lens.
- All modules are performing well, no major issues found Due to wear and tear some parts like hoses, connection and consumables need to be replaced.

## 6.0 Recommendations

- Pro-actively replace parts (e.g. hoses/connections, consumables, periodic maintenance items).
- Periodic Maintenance actions (re-adjustments, cleaning, greasing, etc.)
- Lens Repair (in case ATP spec is required)




## 7.0 Appendices

### 7.1 Performance reports

1	Straylight Uniformity	1/10/2020	out of spec	< 2.5%	3.76%
2	Max Dx	1/10/2020	In spec	< 50	6.5
3	Max DY	1/10/2020	In spec	< 50	8.9
4	Max DX - RES X	1/10/2020	In spec	< 25	0.5
5	Max DY - RES Y	1/10/2020	In spec	< 25	4.5
6	Asym Rot: Correction	1/10/2020	In spec	0 +/- 0.5	-0.016
7	Asym Mag: Correction	1/10/2020	In spec	0 +/- 0.5	0.067
8	Dyn Z Height of Element 1	1/10/2020	In spec	0 +/- 5.0	-2.305
9	Dyn Z Focus Height	1/10/2020	In spec	0 +/- 0.1	0.042
10	Image Tilt Ry	1/10/2020	out of spec	0 +/- 3.0	-4.739
11	LENS QUALIFICATION				
12	Isolated Through Focus	11/27/2019	In spec	≤50nm	26nm
13	Isolated Best Focus	11/27/2019	In spec	≤25nm	17nm
14	Dense Through Focus	11/27/2019	In spec	≤35nm	31nm
15	Dense Best Focus	11/27/2019	In spec	≤25nm	20nm

16



## **8.0 Material list**

### 8.2 Material list (to make system functionally complete)

ELECTRONIC CABINET PANELS	2
---------------------------	---